

INTEGRITY TESTING LABORATORIES,

a division of ErgoLabs, Inc.

CLIENT:

Versa Products
13923 Doty Avenue
Hawthorne, CA 90250
Attn: Chris Stormer

LABORATORY NO: F0604192-3
DATE: April 19, 2006
CLIENT P.O. NO.: Fax, C. Stormer
STANDARD: ANSI/BIFMA X5.5-98

SAMPLE: ONE MOBILE MEDIA/COMPUTER CART,
MODEL, DELUXE DIAGNOSTIC FUSION CART,
TESTED WITH GLIDES AND OPTIONAL CASTERS, MODIFIED PRINTER
PLATFORM AND ASSEMBLY INSTRUCTIONS

ABSTRACT

This report serves to document the testing of the above sample tables to all applicable test paragraphs of ANSI/BIFMA X5.5-1998, tests for office desk and table products. All applicable tests required for complete certification were performed on this sample. The remainder of this report will show how the table submitted for testing **met the requirements** needed for conformance to the stated test paragraphs of the standard.



DELUXE DIAGNOSTIC FUSION CART

3911 E. LaPalma, Suite E, Anaheim Hills, CA 92807 Phone: (714) 630-2363 Fax: (714) 630-2256

This report applies only to the sample or samples submitted for testing and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, or these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed, and upon that condition that it not be used, in whole or in part, in any advertising or publicity matter without prior written authorization from these laboratories.

RESULTS

Test Paragraph	Test Description	Test loads and Cycles	Observations
4.3	Distributed Functional Load	66 lb. load applied evenly on keyboard for a period of 60 minutes	PASS-No failure during or after the load application
4.3	Distributed Functional Load	3.0 lb./in of width, or 55 lb. load evenly on printer shelf for a period of 60 minutes	PASS-No failure during or after the load application
4.4	Concentrated Proof Load	300 lb. load applied 1" from table edge for a period of 15 minutes	PASS-No failure during or after the load application
4.5	Distributed Proof Load	100 lb. load applied evenly on keyboard for a period of 15 minutes	PASS-No failure during or after the load application
12.3	Functional Leg Strength Test	Table was laid on its top and loads of 12 lbs. and 24 lbs. were each applied horizontally within 1" of the end of the leg in two directions	PASS-No loss of serviceability after the performance of the test
12.5	Proof Leg Strength Test	Table was laid on its top and loads of 18 lbs. and 36 lbs. were each applied horizontally within 1" of the end of the leg in two directions	PASS-No sudden major change in the structural integrity of the product
13.3	Stability Test	125 lbs. was applied 1" from table edge at the least stable location	PASS-Unit did not tip over

CONCLUSION

During the execution of the testing program, the Deluxe Diagnostic Fusion Cart with casters or glides, performed well with no structural failures or loss of serviceability. This sample submitted for testing **conforms** to all of the applicable test paragraphs of ANSI/BIFMA X5.5-1998.

Respectfully submitted,



Edwin A. Leach, Project Manager
INTEGRITY TESTING LABORATORIES,
a division of ErgoLabs, Inc.

